

BELZONA SAVES COAL DRYER EXHAUST FAN

CUSTOMER

British Columbia, CA

APPLICATION DATE

April 2014

APPLICATION SITUATION

This fan handles hot exhaust from a gas-fired dryer at a coal mine.

PROBLEM

Exhaust contains fine coal dust and moisture, which erodes the fan blades, including the AR steel blade protectors.

PRODUCTS

Belzona 1311 (Ceramic R-Metal)

Belzona 1391 (Ceramic HT)

SUBSTRATE

AR steel

APPLICATION METHOD

After proper surface preparation, the application was carried out in accordance with Belzona Know-How System Leaflet FBC-1.

BELZONA FACTS

The Belzona rebuild is more cost effective than replacing the AR wear plates. Also, power drawn by the fan motor is dramatically reduced. For these reasons, this has become a regular maintenance procedure on this fan. In this case, the fan rotor had been neglected for several years as it was scheduled for replacement. Unfortunately, the new rotor was not effective so the original one was reinstalled and rebuilt once again with Belzona.

PICTURES

1. Worn out AR plate; Belzona 1311 applied several years prior is still evident. Note missing bolt.
2. Rebuilt and coated with Belzona 1311 and 1391, respectively.
3. Completed application without disassembly and in one shift.
4. Belzona application intact after 6 months in operation.



1.



2.



3.



4.

For more examples of *Belzona Know-How In Action*, please visit <http://khia.belzona.com>



Belzona products are manufactured under an ISO 9000 Registered Quality Management System.

UK • USA • Canada • Thailand
www.belzona.com

