

VOLUTE PUMP INTERNAL LINING REPAIRED WITH CHEMICAL RESISTANT PROTECTIVE COATING

CUSTOMER

Power Plant Ras Laffan Qatar

APPLICATION DATE

Dec-20

APPLICATION SITUATION

The volute pump has been running for 3 years without interruption, resulting to failure of existing internal coating

PROBLEM

Internal lining was severely damaged, general corrosion all over the surface is evident and deep pitting on inlet sitting area and on outlet flange face

PRODUCTS

Belzona 1111 (Super Metal)

Belzona 4311 (Magma CR1)

SUBSTRATE

Carbon steel

APPLICATION METHOD

Surface preparation by grit blasting is carried out to remove rusts and corrosion residues as well as to expose unforeseen pitting to evaluate the amount of caulking material to be used. Rebuilding application on all exposed pitting takes place after blasting is completed and cured for 2 hours. After curing, sweep blasting has been conducted all over the surface which includes the surface of the rebuilding material, followed by application of Belzona 4311 chemical resistant coating in two coat system.

BELZONA FACTS

Using Belzona chemical resistant products provides longer lasting protection, cost effective and easy to apply. It has been proven to this company for several years as only Belzona material gives the client a full satisfaction and the cost of Belzona repair is more competitive than other solutions which makes the client happier considering that the pump will not be replaced with new one which will cost them thousands of dollars.

PICTURES

1. Appearance of the pump before blasting
2. Pump after blasting
3. During coating application
4. Application complete with Belzona 4311



For more examples of *Belzona Know-How In Action*, please visit <http://khia.belzona.com>

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

Copyright © Belzona International Limited 2021


BELZONA[®]
Repair • Protect • Improve