

# Radiator End Cap Refurbishment

ID: 10153

Industry: Power  
Application: HEX-Heat Exchangers  
Substrate: Carbon steel  
Products: Belzona 5811DW (DW Immersion Grade)

Customer Location: Auckland, New Zealand  
Application Date: November 2025

## Problem

The end caps were heavily corroded internally, and leakage at the sealing faces had led to reduced efficiency and the risk of damage to other systems.



This section shows the original condition of the end caps prior to refurbishment.

The surfaces were grit blasted to SSPC-SP10 or ISO Sa 2.5 in accordance with ISO 8501-1.

The surfaces were coated with two coats of Belzona 5811DW (DW Immersion Grade).

The end caps were fully reassembled with washers and are ready to be returned to service.

## Application Situation

The radiator end caps were suffering from corrosion, which was affecting performance. Small leaks had begun to develop at the sealing faces, and the client was concerned that the heat exchanger could fail without immediate attention.

## Application Method

After grit blasting, the internal faces were coated with two coats of Belzona 5811DW (DW Immersion Grade) to protect against future corrosion. New gaskets were manufactured and installed.

## Belzona Facts

The alternative was to replace the heat exchanger, which would have resulted in an extended period of downtime and significant expense, both of which were unacceptable.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015  
FS 695214  
ISO 14001:2015  
EMS 695213

Belzona products are  
manufactured under an ISO  
9000 Registered Quality  
Management System.

[www.belzona.com](http://www.belzona.com)

  
**BELZONA®**  
Repair • Protect • Improve