

COOLING TOWER FAN BLADES REPAIRED WITH BELZONA PRODUCTS

ID: 1445

Industry: General Industry
Application: FBC-Fans, Blowers and Compressors

Customer Location: Fertilizer Producer, Indonesia
Application Date: February 2010

Substrate: GRP
Products: * Belzona® 1311 (Ceramic R Metal) ,
* Belzona® 1321 (Ceramic S Metal) ,
* Belzona® 5811 (Immersion Grade) ,

Problem

Erosion on leading edges, cracks and flaking on trailing edges of cooling tower fan blades caused by UV degradation, erosion and impingement. This reduces the overall efficiency and operation of the cooling system.



Photograph Descriptions

- * Damage on leading edges ,
- * Flaking on trailing edges ,
- * Belzona application ,
- * Completed blades after coating with Belzona® 1321 and Belzona® 5811 ,

Application Situation

GRP fan blades from cooling tower

Application Method

The application was carried out in accordance with Belzona Know-How System Leaflet FBC-1. The Leading edges and trailing edges were rebuilt with Belzona® 1311 and subsequently coated with Belzona® 1321. Blade body was coated using Belzona® 5811.

Belzona Facts

The Belzona refurbishment has avoided the high cost of blade replacement. Each cell contains six blades. The Belzona solution will provide the plant with long term protection of the blades.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA®
Repair • Protect • Improve

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

Copyright © Belzona International Limited 2025

