

## Belzona SuperWrap seals weeping storage tank

ID: 1577

Industry: *Power*  
 Application: *VPF-Valves, Pipes and Fittings*  
 Substrate: *Mild Steel*  
 Products: *\* Belzona® Superwrap ,*

Customer Location: *Energy Company*  
 Application Date: *April, 2009*

### Problem

*Vertical weld was found to be very porous and fuel oil was weeping from a 2 mm through wall defect. No corrosion or thin wall area was detected. Defect was located at 30 feet from the ground level.*



### Photograph Descriptions

- \* Damaged area ,
- \* Area prepared by abrasive blasting ,
- \* Belzona® SuperWrap application ,
- \* Belzona® SuperWrap repair inspected and painted over ,

### Application Situation

220 foot diameter 56 foot high storage tank containing fuel oil at 140°F max. temperature.

### Application Method

SuperWrap composite system was applied in compliance with ISO/TS 24817 and ASME PCC-2. Belzona® Superwrap composite repair system was applied at 10 mm thickness and over a 100 x 355mm area.

### Belzona Facts

The repair was completed without resort to hotwork. Belzona® Superwrap System was inspected in 2010 and found to be in perfect

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015  
 FS 695214  
 ISO 14001:2015  
 EMS 695213

Belzona products are  
 manufactured under an ISO  
 9000 Registered Quality  
 Management System.

[www.belzona.com](http://www.belzona.com)

  
**BELZONA**  
 Repair • Protect • Improve

condition.

---

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015  
FS 695214  
ISO 14001:2015  
EMS 695213

Belzona products are  
manufactured under an ISO  
9000 Registered Quality  
Management System.

[www.belzona.com](http://www.belzona.com)

