# BELZONA RESTORES VALVES TO BETTER THAN NEW CONDITION

ID: 184

Industry: Pulp & Paper Customer Location: Paper Mill in Northwest Florida, U.S.A.

Application: VPF-Valves, Pipes and Fittings Application Date: 1992

Substrate: Cast iron

Products: \* Belzona® 1111 (Super Metal),

\* Belzona® 9411 (Release Agent),

#### **Problem**

Housing had eroded/corroded to the point where the valve flap would not seat (seal) properly, allowing partial flow in the wrong direction







## **Photograph Descriptions**

- \* Corroded housing. ,
- \* Molding technique using fabricated dummy pin, Belzona® 1111 (Super Metal) and Belzona® 9411 (Release Agent) are employed.
- \* Finished repair.,

### **Application Situation**

Swing pin housings of non-return check valves.

# **Application Method**

The application was carried out in accordance with Belzona Know-How Leaflet VPF-7.

## **Belzona Facts**

The customer averted costly replacement or welding and line boring. Several valves were repaired. New flappers were installed and the inside of the valve bodies were rebuilt with Belzona® 1111 (Super Metal).

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

BELZONA®
Repair • Protect • Improve