

BELZONA REPAIRS 315 kW MOTOR SHAFT

ID: 2454

Industry: *Power*
Application: *MPT-Mechanical Power Transmission*

Customer Location: *Siemens, Slovakia*
Application Date: *July 2009*

Substrate: *steel*
Products: ** Belzona® 1111 (Super Metal) ,*

Problem

Shaft had been damaged by failed bearing.



Photograph Descriptions

- * Electric motor case ,
- * Damaged shaft ,
- * Machining of the Belzona® 1111 ,
- * Completed job ,

Application Situation

315 kW electric motor shaft

Application Method

Application was carried out in accordance with Belzona Know-How System Leaflet MPT-1. Shaft was turned down and left with coarse thread before being rebuilt with Belzona® 1111 followed by machining back to original diameter.

Belzona Facts

Welding was not an option due to the high risk of thermal stress. Belzona repaired required no heat so enabled a safe cost effective repair to be completed quickly, saving huge cost over replacement option.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA
Repair • Protect • Improve