

BELZONA UPGRADE TO LARGE TRANSFORMER

ID: 3090

Industry: Power
Application: VPF-Valves, Pipes and Fittings
Substrate: Steel
Products: * Belzona® 1161 (Super UW-Metal) ,

Customer Location: Power plant, North of France
Application Date: January 2012

Problem

Oil was leaking from many of the flanges. Replacing the seals was not an option. This would have required draining the 42 tonnes of oil from the transformer as well as individually dismantling the 70 flange faces, a very time-consuming task.



Photograph Descriptions

- * Original condition of the flange faces ,
- * Repair with Belzona® 1161 and Belzona® 9341 ,
- * Belzona being applied to encapsulate the bolts ,
- * Finished application. ,

Application Situation

70 Flange faces of one of the transformers. Large transformer with no fewer than 70 flanged joints.

Application Method

Application was carried out in accordance with Belzona Know-How System Leaflet VPF-11a.. After the surface was prepared using an MBX Bristle Blaster followed by degreasing the substrate, Belzona® 1161 and Belzona® 9341 (Reinforcement tape) were applied onto the whole surface of the flange faces in order to stem the leaks.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

BELZONA
Repair • Protect • Improve

Belzona Facts

Belzona offered a cost-effective solution to the client to cold-seal the leaking flange faces without the need to drain down the oil. The application only took two weeks to complete, far less than the alternative of replacing the seals, and allowed a quick return in service of the transformer.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

