

BELZONA CAVITATION RESISTANCE FOR IMPELLER

ID: 33

Industry: *Oil & Gas*
Application: *CEP-Centrifugal Pumps*
Substrate: *Bronze*
Products: ** Belzona® 1311 (Ceramic R-Metal) ,*
** Belzona® 1421 ,*

Customer Location: *Oil Refinery in Mississippi*
Application Date: *August 1995*

Problem

Severe damage to the impeller caused by cavitation



Photograph Descriptions

- * Surface preparation—abrasive grit blasting in progress ,
- * Cavitated areas of the impeller rebuilt with Belzona® 1311 ,
- * Application of Belzona® 1421 complete, impeller ready for service ,

Application Situation

40-inch impeller for cooling tower pump

Application Method

The application was carried out in accordance with Belzona Know-How Leaflets CEP-1 and CEP-3.

Belzona Facts

The customer saved a \$45,000 replacement cost for a new impeller.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

BELZONA
Repair • Protect • Improve