# **Belzona Seals A Transformer Lid Flange**

Industry:Oil & GasApplication:VPF-Valves, Pipes and FittingsSubstrate:Carbon SteelProducts:\* Belzona 1291 (ES Metal),<br/>\* Belzona 1221 (Super E Metal),<br/>\* Belzona 1161 (Super UW Metal),

\* Belzona 5831 (ST Barrier),

#### Problem

Most of the gasket had failed around the 10m perimeter of the lid, with oil seeping down the sides and going to ground. Unfortunately it was not possible to drain the oil below the gasket level and so the application had to be pursued as a live leak with a 1m head pressure.

Customer Location: Gas Distributor, UK

Application Date: 2011



## **Photograph Descriptions**

- \* 1. Original condition of flange, with header tank at rear. ,
- \* 2. Encapsulation of bolts with Belzona 1161.,
- \* 3. Completed repair close up.,
- \* 4. Finished work after 3 days. ,

### **Application Situation**

Lid gasket failure resulted in extensive oil leaks around flange on this 66-11Kv transformer.

## **Application Method**

Application was carried using Belzona Know-How System Leaflet VPF-11a as a guide. Area of flange and bolts were pressure cleaned and grit blasted. Live leaks stemmed with Belzona 1291 (ES Metal) and Belzona 1221 (Super E Metal). Bolt heads top and bottom were encapsulated with Belzona 1161 (Super UW Metal). Belzona 1161 (UW Metal) and Belzona 9341 (Reinforcement Sheet) were used to create a reinforced band around the flange. Finally over coated with Belzona 5831 (ST Barrier).

## **Belzona Facts**

The customer was desperate for a fast solution to the problem and whilst there were a couple of very minor leaks still on

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015Belzona products areFS 695214manufactured under an ISOISO 14001:20159000 Registered QualityEMS 695213Management System.

www.belzona.com



ID: 3975

Copyright © Belzona International Limited 2024

completion, these were deemed to be well within acceptable limits. The customer was delighted with the results and is looking to repeat the application to other transformers on their site.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

FS 695214 ISO 14001:2015 EMS 695213

ISO 9001:2015Belzona products areFS 695214manufactured under an ISO 9000 Registered Quality Management System.

www.belzona.com

