

BELZONA SEALS LEAKING CABLE END BUSHING

ID: 4646

Industry: Power
Application: VPF-Valves, Pipes and Fittings
Substrate: Porcelain, Cement, Steel
Products: * Belzona® 1221(Super E-Metal) Belzona® 1161(Super UW-Metal) Belzona® 5831(ST-Barrier),

Customer Location: Electricity substation, UK
Application Date: MAY 2013

Problem

The yellow phase bushing was leaking oil and the uncontrolled release required sealing to allow further planned maintenance of other transformers in the substation to be carried out. The Client opted for a fast in situ repair as opposed to the possible long lead time of replacement and time required for installation which would cause further disruption to the planned maintenance schedule.



Photograph Descriptions

* Original bushing condition. During the application of Belzona® 1291, Belzona® 1221 & Belzona® 1161. Application of the Belzona® 5831. Completed application. ,

Application Situation

Cement joint between porcelain and steel flange had broken down on bushing - Yellow Phase

Application Method

The application was carried out in accordance with Belzona system leaflet VPF-11. After cleaning and abrading the substrate Belzona® 1291 & Belzona® 1221 were used to stem the leak before applying Belzona® 1161 with reinforcement tape. Finally Belzona® 5831 was applied to the repair area.

Belzona Facts

The stemming of the leak was crucial to the client for them to keep within their planned maintenance schedule. The cost comparison of the Belzona solution in time and money was exceptionally competitive compared to replacement. The repair was carried out without the removal of oil and remained under pressure during the application.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

**BELZONA**
Repair • Protect • Improve