

BELZONA REPAIRS SPALLED LINTELS ON SCHOOL

ID: 4734

Industry:

Application: WPA-Wall Problem Areas

Substrate: Concrete

Products: * Belzona 4141 (Magma Build) ,

Customer Location: Primary School, Blackpool, UK

Application Date: February 2012

Problem

Pieces of concrete breaking away from the lintels were deemed a safety hazard and needed urgent solution to be completed during half term school holiday.



Photograph Descriptions

* 1 & 2. Some of the damaged lintels and sills before application 3 & 4. Completed repairs ,

Application Situation

School exposed to local marine environment. A number of concrete lintels and sills, particularly those over-looking the playground and exposed to the prevailing winds and sea spray were in need of urgent refurbishment.

Application Method

Application was carried out in accordance with Belzona System Leaflet WPA-4. Areas were hammer tested to detect early signs of spalling and all loose concrete hacked off to leave solid substrate. Exposed rebar was abraded back to bright metal before building back to original profile with the Belzona 4141 system.

Belzona Facts

The excellent non-slump characteristics allowed the rebuilding to be done quickly without the need for fixed shuttering. Cementitious repairs or replacement could not have been completed in the available time and would have led to un-necessary disruption to the school.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015

FS 695214

ISO 14001:2015

EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA[®]
Repair • Protect • Improve

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

Copyright © Belzona International Limited 2024

