# **Repair Corroded Cooling Tower Pipe with Belzona**

ID: 5414

Industry: Chemical & Petrochemical Customer Location: Petrochemical Plant Southeast Texas

Application: VPF-Valves, Pipes and Fittings Application Date: April 2013

Substrate: Carbon Steel

Products: \* Belzona 1211 (E-Metal),

\* Belzona 1111 (Super Metal),

\* Belzona 4151 (Magma-Quartz Resin),

\* Belzona 5111 (Ceramic Cladding),

\* Belzona 9731,

#### Problem

Non-destructive testing (NDT) showed where heavy corrosion had caused major pitting resulting in thin walled pipe in many areas and through wall in one spot.









# **Photograph Descriptions**

- \* Close-up of heavy corrosion,
- \* Original leak and new through wall due to blast,
- \* Belzona 1111 applied to fill the pits,
- \* Finished project,

### **Application Situation**

3 sections of 30" x 10' Suction Pipe and 3 sections of 30" x 10' Discharge Pipe on Cooling Tower

### **Application Method**

Application carried out in accordance with Belzona Know How System Leaflet VPF-11. After proper surface preparation Belzona 1211 was used to fix the live leak. Belzona 1111 was then used to fill the pitting. Belzona 4151 with Belzona 9731 reinforcement tape were used to form a pipe wrap for stregth. A final coat of Belzona 5111 was used for UV and environmental protection.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com



# **Belzona Facts**

The original plan was to replace 30 linear feet of discharge pipes of 30 inches in diameter at a cost of almost \$90,000 for materials only. The Belzona solution saved the customer over \$75,000 and was completed in just 2 days. It was so successful that and addition 30 linear feet of suction piping was done within 2 weeks saving the plant over \$150,000.

www.belzona.com