

BELZONA STOPS THE LEAK ON FIREWATER SYSTEM


ID: 5430

Industry: Marine
Application: VPF-Valves, Pipes and Fittings
Substrate: Carbon steel
Products: * Belzona 1121 (Super XL Metal) ,
* Belzona 9341 (Reinforcement Sheet) ,

Customer Location: Tank Terminal, South Louisiana, USA
Application Date: September 2014

Problem

The piping was old and had not been taken care of. Many clamps on the lines, but leaks were starting to appear under the clamps. There were other places in the line where actual holes had appeared from corrosion.



Photograph Descriptions

- * 1. One of the holes in the pipe ,
- * 2. Water flowing from the pipe ,
- * 3. Area of the pipe that was leaking ,
- * 4. Application completed ,

Application Situation

Firewater piping at a tank terminal.

Application Method

Application was carried out in accordance with a modified Belzona Know-How System Leaflet VPF-11.

Belzona Facts

Customer is very satisfied with the fact that the pipe will not corrode any more due to the fact a polymer steel now encapsulates the piping. Belzona was picked as other wraps had been tried and failed and the clamps were not sufficient to adequately stop the

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com



leaks.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

