

BELZONA SEALS LEAK IN UNDERWATER OBSERVATION WINDOW

ID: 6289

Industry: *Buildings & Structures*
Application: *FPA-Floor Problem Areas*
Substrate: *Stainless Steel/ Butyl Rubber*
Products: ** Belzona 2211 (MP Hi-Build Elastomer) ,*

Customer Location: *Vancouver, BC*
Application Date: *March 2015*

Problem

The underwater observation window had developed a leak.



Photograph Descriptions

- * 1. View of observation window ,
- * 2. Metal surface prepared ,
- * 3. Perimeter of the window masked off ,
- * 4. Completed application with all tapes removed ,

Application Situation

A leak on the underwater window.

Application Method

The application was carried out in accordance with a modified Belzona Know-How System Leaflet FPA-6. The stainless steel surround was prepared using a grinder to achieve a clean rough profile on the metal surface. After masking off the perimeter, a 1/8 thick rubber tape was used to create a suitable clearance on the inside of the window-sufficient to clear the screw heads.

Belzona Facts

Belzona Elastomer had been used successfully in similar situation.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA®
Repair • Protect • Improve