BELZONA PROTECTS DESALTER FROM CORROSION

ID: 7758

Industry: Oil & Gas Customer Location: Scotland
Application: TCC-Tanks and Chemical Containment Application Date: May 2018

Areas

Substrate: Mild steel

Products: * Belzona 1511 (HT metal),

* Belzona 1523, * Belzona 1593,

Problem

The vessels contained hydrocarbons, salts & wet H2S at high temperature. The previous coating had failed, leaving the vessel exposed to the potential for corrosion.









Photograph Descriptions

- * Osmotic blistering in existing coating,
- * Surface after grit blasting,
- * Belzona 1511 used to pit fill,
- * Two coats of Belzona 1523 applied by spray,

Application Situation

Two desalters had come out of service. Osmotic blistering had been noted on the previous coating within the vessel. A long term solution was required to protect the two vessels from corrosion.

Application Method

The vessels were blasted to SA2.5 & minimum 75 microns using garnet. Salt tests were carried out to ensure the levels were within acceptable limits. Any pits found were filled with Belzona 1511. Hard to spray areas were stripe coated with Belzona 1593. Two coats of Belzona 1523 were then applied. The application was carried out in accordance with Belzona System Leaflet TCC-5.

Belzona Facts

The vessel coating was completed within a tight shutdown window. This method of coating rather than replacing the vessels ensured long term protection with minimal disruption to the plant.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com

BELZONA