

Cooling Water Outlet Protected with Belzona 1321

ID: 7792

Industry: Power
Application: VPF-Valves, Pipes and Fittings
Substrate: Mild steel
Products: * Belzona 1321 (Ceramic S-Metal) ,

Customer Location: Ireland
Application Date: September 2018

Problem

The existing rubber lining had reached its end of life. The existing rubber was no longer providing the steel pipes with protection from erosion/corrosion. The rubber needed to be removed to allow for application of Belzona 1321.



Photograph Descriptions

- * Rubber lining in outlet pipe ,
- * Condition of rubber lining ,
- * Blasting in progress ,
- * Finished Belzona 1321 ,

Application Situation

Sea water used as coolant in open cooling system in coal fired power station. Steel cooling water outlets below the condenser

Application Method

The rubber was stripped. The steel was grit blasted and then washed to removed all salts. The steel was blasted back to ISO 8501 SA 2 1/2 and Belzona 1321 was applied in two coats.

Belzona Facts

Belzona 1321 is substantially cheaper than rubber lining. Belzona 1321 had been used in the past in that station to re-line pipe work and equipment that had been previously rubber lined.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

BELZONA
Repair • Protect • Improve