

Internal refecton of a centrifugal pump using Belzona

ID: 7873

Industry: Fluid Flow

Customer Location: France

Application: CEP-Centrifugal Pumps

Application Date: March 2014

Substrate: Cast Iron

Products: * Belzona 1111 (Super Metal) ,
* Belzona 1311 (Ceramic R-Metal) ,
* Belzona 1811 (Ceramic Carbide) ,
* Belzona 1341 (Supermetalglide) ,

Problem

The inside of this pump was badly damaged by entrained solids as it pumps river water. The high speed of the fluid also accelerated the deterioration.



Photograph Descriptions

- * 1- Overview of the equipment ,
- * 2- Zoom on the main defect on the discharge outlet ,
- * 3- Reinforcement with the metallic net ,
- * 4- Final application ,

Application Situation

Inside of a centrifugal pump

Application Method

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA
Repair • Protect • Improve

The application was carried out in accordance with an adapted version of Belzona Know How System Leaflet CEP-5.

The substrate was first prepared by grit blasting, then Belzona 1111 was used to rebuild the concentric area. It was then machined to get the right tolerances. The discharge outlet was rebuilt from the outside using a metallic mesh and Belzona 1311 and protected with Belzona 1811. Finally the inside of the pump was protected with Belzona 1341.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

