Belzona repairs 6 heat exchangers

ID: 7933

Industry: Oil & Gas Customer Location: Morocco
Application: HEX-Heat Exchangers Application Date: March 2019

Substrate: Steel

Products: * Belzona 1511 (Super HT Metal),

* Belzona 1391T,

Problem

12 tube sheets suffering from corrosion and chemical attack were exposed to elevated temperatures (up to 200°C - Dry Heat) when in service, therefore requiring a full tube sheet rebuild and protection.









Photograph Descriptions

* . Initial Damaged Surface of the Tube Sheet. ,

*

* Surface of the Tube Sheet once Rebuit, ,

,

* Surface of the Tube Sheet once Coated with Belzona 1391T, ,

,

* Final finish of several Tube Sheets.,

.

Application Situation

Heat exchangers within the food industry were corroded and suffered from severe chemical attack.

Application Method

The application was carried out in accordance with Belzona System Leaflet HEX-01. The substrate was grit blasted and cleaned

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

BELZONA

www.belzona.com

using Belzona 9111. All tubes on the tube sheet were corked - using over 6000 corks. The surface of each tube sheet was rebuilt back to it's original profile using Belzona 1511, a conical grinder was used to chamfer the product around each tube. Once rebuilt the tube sheet was coated using Belzona 1391T to prevent corrosion and chemical attack from the Hexane gas. Belzona 1391T is perfect for higher temperature applications such as these where the operating temperature was 120°C (up to 200°C - Dry Heat). Once the tube sheet coated the corks were drilled out and the tube sheet cleaned using compressed air.

Belzona Facts

The only alternative for this piece of equipment would have been to replace the whole of the heat exchanger, replacement was therefore not an option. Belzona was able to not only rebuild the original profile but also prevent future corrosion and protect against chemical attack. 50KG of Belzona 1511 and 21KG of belzona 1391T were used for this project.

