

BELZONA FILLS THE VACUUM

ID: 7997

Industry: Fluid Flow
Application: CEP-Centrifugal Pumps
Substrate: Stainless Steel
Products: * Belzona 4341 ,

Customer Location: Spain
Application Date: June 2013

Problem

Due to chemical attack caused by the sulfuric acid at elevated temperatures, the pump has lost material on all components. As a result the tolerances no longer provide an effective vacuum and the pump is running at low efficiency.



Photograph Descriptions

- * 1. Internal casing after preparation ,
- * 2. Internal casing after coating ,
- * 3. End covers coated ,
- * 4. Impeller coated ,

Application Situation

A vacuum pump in a chemical plant carrying sulfuric acid at elevated temperatures.

Application Method

After cleaning with a solvent degreaser to remove chemical residues, the surface was grit blasted to achieve a surface cleanliness in accordance with Swedish Standard SA 2.5 "Near White Metal". The entire internal surface, end covers, and impeller were coated with 2 layers of Belzona 4341. On the impeller tips, the coating was rebuilt to an excess of 5mm, then machined back to the required tolerances. The application was in accordance with a modified version of Belzona System Leaflet CEP-03 & CEP-07.

Belzona Facts

Belzona 4341 was chosen for its excellent resistance to inorganic acids at elevated temperatures. The 100% solids nature of the product meant that a precise thickness could be applied, easily allowing for the tolerances to be restored to the pump. The efficiency of the pump was fully regained, resulting in significant operating cost savings.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA®
Repair • Protect • Improve