### TWO DAY BELZONA REPAIR TO HEAT EXCHANGER

ID: 839

Industry: General Industry Customer Location: Steel Manufacturer, Jordan

Application: HEX-Heat Exchangers Application Date: May, 2007

Substrate: Steel tube sheet, and cast iron covers.


Products: \* Belzona® 1111 (Super Metal),

\* Belzona® 1321 (Ceramic S Metal),

#### **Problem**

Heat exchanger was suffering bimetallic corrosion (copper tubes, steel tube sheet and cast iron covers), causing leakage on the tube sheet.









## **Photograph Descriptions**

- \* Severe corrosion after surface preparation,
- \* Tube ends sealed during application,
- \* Division bar seal face reformed,
- \* Rebuilding and coating the end cover with division bar,

#### **Application Situation**

Heat exchanger.

# **Application Method**

Application was carried out in accordance with Belzona Know-How System Leaflets HEX-1 & HEX-2.

#### **Belzona Facts**

This application reduced the down time of the factory, because repairing process was accomplished within two days, and there is no other way to fix quickly.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

BELZONA®
Repair • Protect • Improve