

# BELZONA PUMP REPAIR COMPLETED WITH PORTABLE LATHE

ID: 939

Industry: Power  
Application: MPT-Mechanical Power Transmission

Customer Location: Coal Power Plant, West Virginia  
Application Date: March, 2003

Substrate: Steel  
Products: Belzona® 1111 (Super Metal)

## Problem

Damage on packing gland area due to overtightning of packing and contaminated river water



## Photograph Descriptions

\* Damage to cooling tower pump shaft , \* Set up and undercutting shaft , \* Applying Belzona® 1111 , \* Finished shaft repair ,

## Application Situation

Two 14" diameter shafts for cooling towers pumps

## Application Method

Application carried out in accordance with the Belzona Know-How System Leaflet MPT-1. A portable lathe was used to machine shafts in place.

## Belzona Facts

Cost of repairing shafts was less than \$2,000.00, saving thousands on removing, shipping and downtime. The only alternative was flame welding or sleeving costing more and resulting in the possibility of warping the shaft making Belzona® 1111 the best choice.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015  
FS 695214  
ISO 14001:2015  
EMS 695213

Belzona products are  
manufactured under an ISO  
9000 Registered Quality  
Management System.

[www.belzona.com](http://www.belzona.com)

**BELZONA®**  
Repair • Protect • Improve

Copyright © Belzona International Limited 2024