

Belzona Relines Cooling Tower Pan

ID: 9563

Industry: Heating, Ventilation & Air Conditioning
Application: TCC-Tanks and Chemical Containment Areas
Substrate: Carbon steel
Products: Belzona 5815

Customer Location: Nova Scotia
Application Date: May 2024

Problem

The existing coating liner was failing and required replacement.



Previous coating system.



Belzona 9371 fibreglass strips wetted out with Belzona 5815 to bridge joints.



First coat of Belzona 5815 beige.



Second coat of Belzona 5815 grey.

Application Situation

Belzona 5815 was used as it was a simple, flexible, one product solution to protect the cooling tower pan from corrosion and minor chemical attack.

Application Method

Belzona 5815 was used to wet out strips of Belzona 9371 fibreglass reinforcement to seal seams and joints. Belzona 5815 was then used as a two coat system first by applying beige as the first coat, the grey as the top coat. The Belzona 5815 coating was then cured at ambient temperatures for approximately 10 days before the cooling tower was refilled.

Belzona Facts

A flexible coating was required to bend and move with the thin gauge steel, vibration, and to bridge seams in the cooling tower pan.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA[®]
Repair • Protect • Improve