## Belzona repairs cracked flange

ID: 9574

Industry: Pulp & Paper Customer Location: Castlegar

Application: VPF-Valves, Pipes and Fittings Application Date: September 2024

Substrate: Cast Iron

Products: Belzona 1311 (Ceramic R-Metal), Belzona 2141 (ACR-Fluid Elastomer)

Problem

Overtighten flange led to cracked and damaged flange.









Equipment damage

Surface preparation completed Rebuilt with Belzona 1311

Coated with Belzona 2141 for longevity

## **Application Situation**

Flange cracked and was very damaged needed to get repairs during a 48hr shutdown

## **Application Method**

Cracked drill stopped and vee out. Prepares with grinding tools and cracks filled with Belzona 1311 and cloth. Overcoated with Belzona 2141 to provide expansion and contraction protection

## **Belzona Facts**

Fast and efficient application for repair of a cast iron flange that was tile lined. Welding was not an option

