BELZONA REBUILDS WASTEWATER PUMP IMPELLER

ID: 1116

Industry: Water / Wastewater Customer Location: Water treatment plant, Des Moines,

Iowa U.S.A.

Application: CEP-Centrifugal Pumps Application Date: May 2008

Substrate: Steel

Products: <div>Belzona® 1111 (Super Metal)</div><div>Belzona® 1321 (Ceramic S Metal)</div>

Problem

The impeller was badly eroded and damaged due to grit and solids running through the pump









Photograph Descriptions

* Damaged impeller after being baked and grit blasted, * Impeller with wire mesh in place to support Belzona and help form profiles, * Profiles restored with Belzona® 1111, * Rebuilt impeller being balanced,

Application Situation

Pump impeller handling raw water.

Application Method

The applications was carried out in accordance with Belzona Know-How System Leaflet CEP-1 & -3.

Belzona Facts

Belzona was chosen to rebuild the impeller at a fraction of the replacement cost.

