BELZONA REBUILDS STAINLESS STEEL PUMP

ID: 1277

Industry: Pulp & Paper Customer Location: Pulp & Paper Plant, Bulgaria

Application: CEP-Centrifugal Pumps Application Date: August, 2008

Substrate: Stainless Steel

Products: * Belzona® 1111 (Super Metal),

* Belzona® 1311 (Ceramic R-Metal),

Problem

Loss of internal profiles of the pump casing as a result of corrosion and erosion processes leading to reduced pump efficiency









Photograph Descriptions

- * Damage to the pump casing after blasting,
- * Rebuilding damage inside the casing,
- * Flat metal plate used as former to rebuild flange faces,
- * Pump rebuild completed,

Application Situation

Double end suction centrifugal pump in pulp production

Application Method

Application was carried out in accordance with Belzona Know-How system Leaflets CEP-1 and CEP-5. After blasting with Aluminium Oxide grit the internal damage was restored with Belzona® 1311. Flange faces & sealing ring seats were rebuilt by forming technique with Belzona® 1111.

Belzona Facts

Rebuilding and contouring to the original pump profile restored pump efficiency and saved time for delivery and high replacement costs for a new pump.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

BELZONA®
Repair • Protect • Improve