

# BELZONA PROVEN CAVITATION PROTECTION TO FRANCIS TURBINE

ID: 1441

Industry: Power Customer Location: Hydroelectric plant, Slovakia

Application: CEP-Centrifugal Pumps Application Date: 2004 and 2007

Substrate: Cast Iron

Products: \* Belzona® 1311 (Ceramic R Metal) Belzona® 1341 (Supermetalglide) Belzona® 2141 (ACR Elastomer) ,

#### Problem

Cavitation had caused erosion of the metal and loss of turbine performance. Belzona® 1311 and Belzona® 1341 had been applied in 2004, but had suffered further cavitation, so system upgraded by applying more cavitation resistant Belzona® 2141.









### **Photograph Descriptions**

- \* Cavitation damage to turbine runner ,
- \* Belzona® 1341 showing some cavitation damage ,
- \* Belzona® 2141 being applied to the runner,
- \* After 24 months service Belzona® 2141, inspection shows no further cavitation damage,

### **Application Situation**

Francis turbine runner, 800mm diameter, 40-50m head and optimum 600rpm. Power output 2.1MW with 4m³/s flow rate.

## **Application Method**

Application was carried out in accordance with Belzona Know-How System Leaflets CEP-3 and CEP-10

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

BELZONA®
Repair • Protect • Improve

### **Belzona Facts**

Inspection of the Belzona Ceramic coating in 2006 showed damage from cavitation, so specification was changed to Belzona® 2141. Futher inspection after 2 years showed no damage on the turbine runner.

In 2013 small areas of coatig damage were repaired with further Belzona 2141.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com