# **BELZONA SEALS LEAKS ON SUPERGRID TRANSFORMER**

ID: 2787

Industry: Power Customer Location: UK

Application: VPF-Valves, Pipes and Fittings Application Date: April 2011

Substrate: Steel

Products: \* Belzona® 1161 (Super UW-Metal),

\* Belzona® 5831 (ST Barrier),

### Problem

The transformer was leaking through the bolt holes along the flange face.









# **Photograph Descriptions**

- \* PVC pipe being cut into sections to cover bolts ,
- \* Surface preparation using MBX Bristle Blaster,
- \* The Belzona® 1161 encapsulated bolts ,
- \* Completed application with Belzona® 5831 applied ,

## **Application Situation**

A Super Grid Transformer was Leaking. Such transformers are used on the 400 or 275kV grid.

# **Application Method**

Application was carried out using a modified version of Belzona Know-How System Leaflet VPF-11a. after preparing the metal with an MBX Bristle Blaster, Belzona® 1161 was then used to seal the bolts using PVC pipe of a wider diameter placed over the bolts and filled with the Belzona until totally encapsulated. Once cured, The PVC cups were cut away so that the entire flange could then be covered with Belzona® 5831 to provide overall corrosion protection.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

BELZONA®
Repair • Protect • Improve

# Belzona Facts The application was a success and has been in service for over 8 months now with no signs of leakage, leading to further business with the same client on more of their assets.