BELZONA REPAIRS DEWATERING CENTRIFUGE

Customer Location: Wastewater treatment plant in California U.S.A. Application Date: February 2001

ID: 291

Application:SHM-Solids Handling MachinerySubstrate:Carbon SteelProducts:* Belzona® 1111 (Super Metal) ,
* Belzona® 1811 (Ceramic Carbide) ,

Water / Wastewater

Problem

Industry:

Sludge constantly got behind wear tiles which caused corrosion as well as erosion of the flights. The unit became unbalanced and tiles frequently delaminated, requiring constant maintenance consisting of welding and retiling.



Photograph Descriptions

- * Applying Belzona® 1111 (Super Metal) to tiles ,
- * Fastening tiles to the flights ,
- * Tiles installed along circumference of flights ,
- * Belzona® 1811 applied over bolts and inlet port areas ,

Application Situation

Worn flights on a Humboldt Dewatering Centrifuge.

Application Method

The application was carried out in accordance with Belzona Know-How System Leaflet SHM-7.

Belzona Facts

This application took place at the largest wastewater facility in the coun-try. By using Belzona, it protected the flights and extended the time between routine servicing and maintenance.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 FS 695214 ISO 14001:2015 EMS 695213

Belzona products are manufactured under an ISO 9000 Registered Quality Management System.

www.belzona.com

