# BELZONA REPAIRS CORRODED GAS PIPE AT BOILER HOUSE

ID: 3014

Industry: Buildings & Structures Customer Location: University, Manchester UK

Application: VPF-Valves, Pipes and Fittings Application Date: February 2012

Substrate: Iron

Products: \* Belzona® 1161 (Super UW Metal),

\* Belzona® 5831 (ST Barrier),

#### **Problem**

Following asbestos removal several years ago, a section of a gas main pipe had been left exposed to water ingress from above and as a result had suffered corrosion and metal loss. The client required a solution that was quick, easy and safe to apply to a live gas pipe, that would replace the metal loss and provide lasting protection from further corrosive attack.









## **Photograph Descriptions**

- \* The entry point of the Gas pipe via a service tunnel making acces and application difficult,
- \* Close up of corroded section of pipe,
- \* Completion of Belzona® 1161 application,
- \* Completion of application including final coat of Belzona® 5831,

### **Application Situation**

Main gas feed pipe to boiler house at large University building.

## **Application Method**

The application was carried out in accordance with a modified version of Belzona Know-How System Leaflet VPF-11. Belzona® 1161 was applied to rebuild and protect the badly corroded section of the pipe followed by a heavy coat of Belzona® 5831 for added corrosion protection.

## **Belzona Facts**

Belzona® 1161 and Belzona® 5831 were chosen for their surface tolerant properties. The alternative would have been to remove the corroded section of pipe which would have proved a very lengthy, labour intensive and costly procedure. The Belzona

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com



application took approximately 5 hours to complete spread over two days.	

www.belzona.com