BELZONA PROTECTS LARGE BUTTERFLY VALVE

ID: 408

Industry: Power Customer Location: Power station - Ireland

Application: VPF-Valves, Pipes and Fittings Application Date: 2003

Substrate: Cast Iron

Products: * Belzona® 1311 (Ceramic R-Metal),

* Belzona® 1321 (Ceramic S-Metal),

Problem

Severe erosion-corrosion on the body and particularly the valve disc.









Photograph Descriptions

- * Valve removed,
- * Degree of erosion on the disc clearly evident,
- * Application underway,
- * Completed application ,

Application Situation

Butterfl y valve from cooling water system.

Application Method

Application was carried out in accordance with Belzona Know-How System Leaflets VPF-1 and VPF-2.

Belzona Facts

Weld repairs were not considered viable on the cast iron valve body. Belzona was the only cost effective alternative to replacing the valves at a cost of approximately €20,000 (\$24,000).

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015

Belzona products are
FS 695214

ISO 14001:2015

Belzona products are
manufactured under an ISO
9000 Registered Quality
EMS 695213

Management System.

BELZONA®
Repair • Protect • Improve