

BELZONA REPAIRS HIGH VOLTAGE BREAKER

ID: 5233

Industry: Power

Customer Location: New England, USA

Application:


Application Date: Summer 2010

Substrate: Cast Aluminum

Products: * Belzona 1111 (Super Metal) ,

Problem

The aluminum casting on a SF6 High Voltage Breaker cracked, causing coolant to leak out and create a dangerous operating situation. Dismounting and replacing the breaker was not an option as no spare breaker was available for months.



Photograph Descriptions

- * Overview of the converter station ,
- * The leaking area ,
- * Completed surface preparation ,
- * Completed application ,

Application Situation

SF6 High Voltage Breaker.

Application Method

The surface preparation was carried out with a hand tool grinder and the application was done in accordance with Belzona Know-How System Leaflet TCC-1.

Belzona Facts

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015

Belzona products are

FS 695214

manufactured under an ISO

ISO 14001:2015

9000 Registered Quality

EMS 695213

Management System.

www.belzona.com



Outages are scheduled months in advance and require Grid operator approval. The station was in a scheduled outage when the leak was discovered. No replacement was immediately available so Belzona 1111 was used to get the plant back on-line on schedule, thus saving thousands of dollars.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com

