BELZONA REPAIRS PVC PUMP

ID: 559

Industry: General Industry
Application: CEP-Centrifugal Pumps

Substrate: PVC

Products: * Belzona® 1111 (Super Metal),

Problem

Cracked casing





Customer Location: Construction company - Egypt

Application Date: September 2003



Photograph Descriptions

- * The crack in the PVC pump,
- * Stabilising the crack,
- * Cracks after preparation,
- * Cracks repaired,

Application Situation

PVC dosing pumps (2)

Application Method

Application was carried out in accordance with a modified version of Belzona Know-How System leaflet CEP-6. The cracks were stabilized by drilling and widening it then filled with Belzona® 1111.

Belzona Facts

PVC cracks are critical problems, welding cannot be used here. Belzona stops the cracks in a short time saving the high costs of new units.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com