HOTEL HOT WATER TANK RESCUE WITH BELZONA

ID: 5780

Industry: General Industry Customer Location: Oklahoma, USA
Application: TCC-Tanks and Chemical Containment Application Date: October 2013

Areas

Substrate: Carbon Steel

Products: * Belzona 1111 (Super Metal),

* Belzona 5891 (HT Immersion Grade),

Problem

The hot water tank had been built into the mechanical room in a way that it was impossible to remove and replace it without resituating the whole set up of the room. It had sufficient damage on the interior due to corrosion and buildup of minerals and sediment over the years.









Photograph Descriptions

- * Hot water tank in the back corner of the mechanical room ,
- * Interior of the tank showing the corrosion and buildup of sediment,
- * Interior repaired and ready for coating,
- * Tank repaired and coated, looking like new!,

Application Situation

Potable hot water tank at a large hotel.

Application Method

The application was carried out in accordance with Belzona Know-How System Leaflet TCC-5. The substrate was first cleaned of loose debris with a chipping hammer then sandblasted to near white metal SSPC-10. It was tested for chlorides. All pitting and weld seams were filled with Belzona 1111, which accounted for about 90% of the substrate surface. Then it was coated with a dual coat system of Belzona 5891.

Belzona Facts

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com



	nd coat this in place sav			
For more evamples of Polace	na Know - How In Action, plea	ase visit https://khia.holzo	na com	
or more examples of belzor	ia know Trow in Action, piec	ase visit https://kilia.bel20	Harcotti	

ISO 9001:2015

Belzona products are
FS 695214

ISO 14001:2015

EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com