BELZONA RESTORES AND PROTECTS CORRODED PIPEWORK

ID: 6077

Industry: Steel & Metal Processing Customer Location: Steel plant, Czech Republic

Application: VPF-Valves, Pipes and Fittings Application Date: 2012

Substrate: Steel

Products: * Belzona 1111 (Super Metal),

* Belzona 5831 (ST-Barrier),

* Belzona 5811 (Immersion Grade),

* Belzona 9341 (Reinforcement Tape),

Problem

The lower part of the outer casing of the cooling circuit pipe was heavily corroded, causing a weakening of the actual mantle and localised coolant leak.







Photograph Descriptions

- * Corroded pipework,
- * Belzona 1111 and reinforcing metal plates applied,
- * Pipeline@coated with Belzona 5811 incorporating Belzona 9341,

Application Situation

Corrosion on the inlet and outlet pipes of the cooling circuit

Application Method

Application was carried out in accordance with Belzona Know-How System Leaflets VPF-2 and VPF-11. After surface preparation, the badly corroded areas were repaired with Belzona 1111 and reinforcing metal plates. The pipeline was then treated with the Belzona 5831 and Belzona 5811 incorporating Belzona 9341 to provide long term corrosion protection.

Belzona Facts

Replacing the pipework outright would have been hugely expensive and demanded an extensive period of downtime. Similarly, effecting basic welding repairs would have required lengthy shutdown, incurred additional health and safety risks, and would not

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com

BELZONA®

hat provided a long-t			