

Oil Tank Leak- Power Plant

ID: 7865

Industry: Oil & Gas

Application: MPT-Mechanical Power Transmission

Customer Location: Ghana


Application Date: October 2018

Substrate: Carbon Steel

Products: * Belzona 1212 ,

Problem

The down deck of the tank had been subjected to severe corrosion leading to drips leak of the oil. This needed to be fixed urgently for the plant to continue operating and also avoid environmental hazards from leaking oil.



Photograph Descriptions

- * Oil tank leak area ,
- * During application of Belzona 1212 to the pinhole on the oil tank ,
- * Belzona 1212 application completed. ,

Application Situation

Steel tank Oil Reservoir

Application Method

Surface was blasted using Bristle Blaster to remove existing paint and achieve minimum surface profile and cleanliness. Belzona 1212 was applied to seal the leak by cold bonding. Belzona 1212 was re-applied when the first coat reaches its pre-curing time. This application was done overnight because client needed the tank ready in the morning to receive product and thus no plant shutdown.

Belzona Facts

The oil tank was brought back in service without any delays, saving the client lots of money and kept the plant running. Also, Belzona 1212 was chosen and applied because of the excellent surface tolerant and fast curing properties.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015

FS 695214

ISO 14001:2015

EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA®
Repair • Protect • Improve