

# Rubber Lined Condenser Water Box Repair Requires Belzona

ID: 7880

Industry: Power

Customer Location: Power Plant, Western Region of Saudi Arabia

Application: WPA-Wall Problem Areas


Application Date: 2017

Substrate: Steel

Products: \* Belzona 1311 (Ceramic R-Metal) ,

## Problem

Inspection during the Power Plant shutdown showed severe erosion on the rubber-lined condenser water box, with thickness loss of around 5-6 millimeters in localised areas.



## Photograph Descriptions

\* 1. Application overview 2. Close up of damage showing erosion and cavitation damage 3. The water box repaired with Belzona 1311 (Ceramic R-Metal) ,

## Application Situation

Condenser Water Box

## Application Method

The repair was completed in accordance with system leaflet WPA-1. The rubber was undercut and all loose surface contamination was removed. After achieving correct surface preparation, Belzona 1311 (Ceramic R-Metal) was applied and contoured to the required profile.

## Belzona Facts

One year later, the application is performing very well and working without any problems.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015  
FS 695214  
ISO 14001:2015  
EMS 695213

Belzona products are  
manufactured under an ISO  
9000 Registered Quality  
Management System.

[www.belzona.com](http://www.belzona.com)

  
**BELZONA®**  
Repair • Protect • Improve

Copyright © Belzona International Limited 2025