

Biomass plant pipe repairs

ID: 8163

Industry: Customer Location: Scotland Power Application: VPF-Valves, Pipes and Fittings Application Date: January 2020

Substrate: Carbon steel

Products: Belzona 1982 (SuperWrap II)

Problem

Welding was not an option in this environment & the plant was keen to keep this tank running as the majority of the plant's operation depended on it.









Surface preparation underway SuperWrap 2 consolidated

Completed repair

Repair in place 5 years later

Application Situation

Following NDT testing of a digestor feedpipe, it was found that internal corrosion has caused the pipe wall thickness to approach the minimum allowance. A repair was required to reinforce this pipe without shutting down & dismantling the pipework.

Application Method

The area was prepared to SSPC SP11 using a mechanical abrasion cleaning process. Belzona 1982 was applied along with Belzona 9381 composite reinforcing sheet. A wrap system was applied to the feedpipe along with a patch system terminating onto the tank. Bracket bolts were patched around. The repair was then consolidated with Belzona 9382. The repair was done on a 'standard' SuperWrap II basis.

Belzona Facts

Using this system was much safer than welding & much quicker than dismantling & replacing the pipework. The repair was viewed onsite 5 years following the application & is in good condition.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are FS 695214 manufactured under an ISO ISO 14001:2015 9000 Registered Quality EMS 695213 Management System.

