CAVITATION DAMAGE IN PUMP REPAIRED

ID: 837

Industry: Power Power Customer Location: Power Plant / NE Oklahoma

Application: CEP-Centrifugal Pumps Application Date: March 2007

Substrate: Cast carbon steel (5% Nickel)

Products: * Belzona® 1221 (Super E-Metal) ,

* Belzona® 2141 (ACR Elastomer),

Problem

Severe cavitation erosion above and below wear ring. limited time to restore pump.









Photograph Descriptions

- * Extent of cavitation damage to suction bell, above and below wear ring ,
- * Repairing damage back to original dimensions ,
- * Repaired surface rebated, taped and half coated with Belzona® 2141,
- * Finished job ready for bushing installation then into service,

Application Situation

Suction bell of pump found to be cavitated during 1 week outage.

Application Method

Application carried out in accordance with Belzona Know-How System Leaflets CEP-3 and CEP-5. Rebate grooves were cut to terminate coating.

Belzona Facts

Belzona repair and protective coating combined with 1-week turnaround saved approx. \$15,000 versus purchase of new unit with much longer lead time. Improved resistance to cavitation anticipated.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015

Belzona products are
FS 695214

ISO 14001:2015

Belzona products are
manufactured under an ISO
9000 Registered Quality
EMS 695213

Management System.

BELZONA®
Repair • Protect • Improve