# **BELZONA RESTORES TWO PUMP IMPELLERS**

ID: 850

Industry: General Industry Customer Location: Oyster culture, The Netherlands

Application: CEP-Centrifugal Pumps Application Date: April 2007

Substrate: Bronze

Products: \* Belzona® 1111 (Super Metal),

\* Belzona® 1321 (Ceramic S-Metal),

#### **Problem**

The two impellers had severe damage because a large bolt was left in the inlet of the pump









## **Photograph Descriptions**

- \* Damaged impeller,
- \* Stainless steel infill plates,
- \* Belzona® 1111 used to bond plates and restore profiles,
- \* One repaired alongside one still to be repaired,

### **Application Situation**

Pumps used in oyster cultivation

# **Application Method**

Application was carried out in accordance with Belzona Know-How System Leaflets CEP-1 & 3. Steel plates were formed to recreate the lost vanes. Wire mesh was also incorporated into the Belzona rebuild as the original profile was restored. Repair was coated with Belzona® 1321 to give additional smoothness and erosion protection.

## **Belzona Facts**

Replacement impellers were not available in the time scale required to maintain the Oyster production.

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

www.belzona.com

BELZONA®