Belzona prevents prolonged shutdown due to sulfuric acid flange leak

ID: 8857

Industry: General Industry Customer Location: Chemical Manufacturer, Warrington

Application: VPF-Valves, Pipes and Fittings Application Date: August 2022

Substrate: Steel

Products: * Belzona 1392 (Ceramic HT2),

Problem

The client had an emergency shut down due to hot sulphuric acid leaking from a flange which had previously been coated with a fluoropolymer. The job was very small but was enough to shut the plant down as the existing coating had failed causing a serious and dangerous leak.







Photograph Descriptions

- * 1. Areas of concern,
- * 2. Close-up of the fluoropolymer coating,
- * 3. Belzona 1392 repair,

Application Situation

Damaged flange in a suction chamber.

Application Method

The flange was taken out of service and taken to the Belzona workshop in Wrexham for repair. The applications team prepared the defective areas using mechanical tools to make the surface as rough as possible, angle out the grooves and get down to steel where possible. The surface was also cleaned and degreased prior to the application of a thick coat of Belzona 1392. The product was

For more examples of Belzona Know - How In Action, please visit https://khia.belzona.com

ISO 9001:2015 Belzona products are
FS 695214 manufactured under an ISO
ISO 14001:2015 9000 Registered Quality
EMS 695213 Management System.

BELZONA®
Repair • Protect • Improve

applied level with the remainder of the flange face to ensure the gasket sat tightly on the surface. Once the product had cured, the component was transported back to the customer's facility.

Belzona Facts

The sites operating conditions were a maximum of 40% concentration of Sulfuric acid at 55°C making a high build coating of Belzona 1392 the ideal repair solution. Inspection reports from the site after a weekend in service deemed the repair to be very successful. The overall cost of the repair was less than £800 total.